

Project Learn And Prosper Clacton

DOOR 1 (NEXT TO 2 NO FIRE EXIT DOORS)

Tuesday, 07 October 2025

Prepared For Ssp Compliance

10 Issues Identified



Issue 1 Strips Missing/Ease Abd Adjust Closer/Adjust Gaps To Perimeter Of Door / Add Lipping To Bottom Of Door



Issue 2 Add New Intumescent Strips



Issue 3 Lip Bottom Of Door



Issue 4 Gaps Adjusted



Issue 5 Gaps Adjusted



Issue 6 Gaps Adjusted



Issue 7 Gaps Adjusted



Issue 8 Gaps Adjusted



Issue 9 Gaps Adjusted



Issue 10 Door Complete